

EU - Konformitätserklärung

EU – Declaration of Conformity / UE – Déclaration de Conformité

Der Hersteller / The manufacturer / Le fabricant



Schillerstrasse 17
35102 Lohra-Altenvers¹

erklärt in alleiniger Verantwortung, dass sein Produkt / declares under his sole responsibility, that his product /
déclare sous sa seule responsabilité, que son produit

ExConnection Rail - T04...

gekennzeichnet mit / marked with / marqué avec

Gas:

Ex II 2G Ex db IIC T6 Gb

Dust:

Ex II 2D Ex tb IIIC T80°C Db

Optional and additional type of Protection markings for all Types:

[op is] = for models with [op is] FOC connectors,
mb = for models with HF Barrier
eb = for models with Ex-e terminal box

[op pr] = for models with [op pr] FOC Connectors
[ia Ga/Da] = for models with [ia Ga/Da] intrinsically safe circuits
[ib Gb/Db] = for models with [ib Gb/Db] intrinsically safe circuits

The explosion group can be downgraded to IIB if required

The ambient temperature range can be downgraded if required

The temperature class (gas) and the temperature value (dust) can be downgraded if required.

bescheinigt mit EG-Baumusterprüfbescheinigung / certified by EC type examination certificate /
ayant fait l'objet de l'attestation CE de type

TÜV 10 ATEX 7969 X

auf das sich diese Erklärung bezieht, mit der/den folgenden Richtlinien, Normen oder normativen Dokumenten übereinstimmt:
referred to by this declaration is in conformity with the following directives, standards or normative documents:
auquel se rapporte la présente déclaration, est conforme aux directives, normes ou aux documents normatifs suivants:

Richtlinien/ Directives/ Directives

ATEX	2014/34/EU / 2014/34/EU / 2014/34/EU
ROHS	2011/65/EU / 2011/65/EU / 2011/65/EU
LVD	2014/35/EU / 2014/35/EU / 2014/35/EU
EMC	2014/30/EU / 2014/30/EU / 2014/30/EU

Related Ex Standards

EN IEC 60079-0:	2018
EN 60079-1:	2014
EN 60079-7:	2015
EN 60079-11:	2012
EN 60079-18:	2015
EN 60079-28:	2015
EN 60079-31:	2014

SAMCON Prozessleittechnik GmbH
Schillerstraße 17
D-35102 Lohra-Altenvers

www.samcon.eu
I: +49 6426-9231 0 / F: +49 6426-9231 31

Dipl.-Ing. Steffen Seibert
Geschäftsführer

Altenvers, den / the / le 13.11.2023

¹ benannte Stelle / organisme notifié / notified body: DEKRA Testing and Certification GmbH (0158)